

MSU South Campus Anaerobic Digester ***2 Years of Operation Experience***

Dana Kirk, Ph.D., P.E.

Biosystems and Agricultural Engineering

Anaerobic Digestion Research and Education Center

Michigan State University



South Campus Anaerobic Digester Site



- Sustainability Plan (2011)
 - Significant recycling efforts, lacked options for organics
 - Campus food waste is approximately 1.80 lb/person/day (**3x US average**)
- Energy Transition Plan (2012)
 - South Campus Anaerobic Digester first project (2012)
 - 2015 renewable energy target of 15%
 - 2015 30% reduction in GHG emissions
 - 2015 end of the “coal era”
 - 2016 20 MW solar array planned
- MSU is leader in education, research & outreach



- **Campus Living**

- Roughly 17,000 students live on campus
- Culinary Services serves over 37,000 daily, 152,000 weekly
- 9 dining halls have all access from 7AM to 12AM
- 23 coffee shops/convenience stores/retail foods

- **University Farms**

- Dairy, Swine, Beef, Sheep, Poultry, Equine
- Pavilion





- Digester tank
 - 52' * 26' plus cover (400,000 gallons)
- Digestate storage tank
 - 101' * 42' plus cover (2.1 million gallons)
- CHP system
 - 400 kW electrical production & 450 kW of thermal energy recovery
 - Offset power at 8 to 10 south campus facilities
 - Thermal energy used to sustain the process, heat support building and separator area
- Digestate
 - Separated solids to compost
 - Separated liquid to storage and land application



- Feedstock variability
- O&M challenges
- Mechanical changes
- Operational data





Feedstock	TS (%)	Planned	
		(ton)	(%)
Dairy manure	12	7,000	43
Fruit & vegetable	11	3,900	24
FOG	20	5,000	30
Cafeteria food waste	10	750	3
TOTAL		16,650	



Pre Consumer
Food Waste



Post Consumer
Food Waste



Fruit & Vegetable
Waste




FOG

Feedstock	TS (%)	Planned		2014	
		(ton)	(%)	ton)	(%)
Dairy manure	12	7,000	43	16,000	67
Fruit & vegetable	11	3,900	24	2,900	12
FOG	20	5,000	30	4,400	19
Cafeteria food waste	10	750	3	430	2
TOTAL		16,650		23,730	



Digester Feedstock Deliveries



Feedstock	TS (%)	Planned		2014		2015	
		(ton)	(%)	ton)	(%)	(ton)	(%)
Dairy manure	12	7,000	43	16,000	67	9,525	43
Fruit & vegetable	11	3,900	24	2,900	12	2,900	13
FOG	20	5,000	30	4,400	19	3,730	17
Cafeteria food waste	10	750	3	430	2	440	2
Milk processing waste	12					5,475	25
Packing material	90					60	
TOTAL		16,650		23,730		22,070	

Other materials include waste feed, eggs and one-offs

- Dilution (FOG)
- Particle size (F&V waste)
- Temperature (F&V waste)
- Debris/inorganics
 - Stones/grit
 - Hammers/saw blades
 - Grill grates/salad tongs
 - Plastics
 - Gloves





- Estimated O&M - \$107,000
 - Range of bidders \$35,000 to \$107,000
 - Mean was \$40,000



- Estimated O&M - \$107,000
 - Range of bidders \$35,000 to \$107,000
 - Mean was \$40,000
- Actual O&M approximately \$215,000
 - General maintenance - \$25,000




- Estimated O&M - \$107,000
 - Range of bidders \$35,000 to \$107,000
 - Mean was \$40,000
- Actual O&M approximately \$215,000
 - General maintenance - \$25,000
 - Labor - \$131,500
 - M-F averaging 12 hours per day
 - S-S averaging 5 hours per day (not anticipated)
 - Includes contract negotiations/billing/report



- Estimated O&M - \$107,000
 - Range of bidders \$35,000 to \$107,000
 - Mean was \$40,000
- Actual O&M approximately \$215,000
 - General maintenance - \$25,000
 - Labor - \$131,500
 - M-F averaging 12 hours per day
 - S-S averaging 5 hours per day (not anticipated)
 - Includes contract negotiations/billing/report
 - CHP - \$42,000 (\$0.015/kWh)
 - Premature spark plug failure (700-1000 hrs), cost \$180
 - Current spark plug life between 2,000 & 4,000 hrs



- Estimated O&M - \$107,000
 - Range of bidders \$35,000 to \$107,000
 - Mean was \$40,000
 - Actual O&M approximately \$215,000
 - General maintenance - \$25,000
 - Labor - \$131,500
 - M-F averaging 12 hours per day
 - S-S averaging 5 hours per day (not anticipated)
 - Includes contract negotiations/billing/report
 - CHP - \$42,000 (\$0.015/kWh)
 - Premature spark plug failure (700-1000 hrs), cost \$180
 - Current spark plug life between 2,000 & 4,000 hrs
 - AD mixers - \$18,000 - \$27,000
 - Confined space entry, 2x per year
 - Considering alternative options to reduce service intervals
- 



Complete/in process

- Inline grinder addition
- Plumbing/process flow changes
 - Installation of cleanouts
 - Raised piping above grade
 - Facilitate service
 - Reduced line friction (90° elbows)
- Mix tank mixer replacement
- Insulation of biogas cleanup
- Premature CHP major service



Planned

- Installation of depackaging equipment
- Digester mixer modification
 - Service
 - Energy efficiency
- Nutrient separation







Year	Temp (°F)	pH	OLR (g VS/L-d)	Biogas (scfm)	Methane (%)	Electrical (kW/hr)
2014	103.0	7.9	3.14	54	63.4	199
2015	103.7	7.4	3.52	82	61.3	260



2015 OLR & kWh






2015 Biogas Quantity & Quality



- Electrical energy – 3,000 MW/yr
 - 10% of energy produce needed to operate system
 - 7.3% of the 2015 energy transition goal (based on 08-09)
 - Renewable energy certificates – 3,000 MW/yr
- Thermal energy – +3,000 MW/yr
 - <50% of the thermal energy needed to maintain temperature
- Greenhouse gas reduction (carbon credits)
- Landfill & wastewater diversion ($\approx 14,500$ ton/yr)
- Recycling of carbon and nutrients



- Electrical energy – 3,000 MW/yr **2,600 MW/yr**
 - 10% of energy produce needed to operate system
 - 7.3% of the 2015 energy transition goal (based on 08-09)
 - Renewable energy certificates – 3,000 MW/yr
- Thermal energy – +3,000 MW/yr 
 - <50% of the thermal energy needed to maintain temperature
- Greenhouse gas reduction (carbon credits) 
- Landfill & wastewater diversion **12,500 ton/yr**
- Recycling of carbon and nutrients 



Dana Kirk, Ph.D., P.E.
P: 517.432.6530
E: kirkdana@msu.edu

